

Type Approval Certificate



This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the GL Type Approval System.

Certificate No. 15 667 - 00 HH

Company häwa GmbH & Co. KG
Industriestraße 12
88489 Wain, GERMANY

Product Description (1) Housing , (2) Console, (3) Junction boxes, (4) Housing

Type (1) SN (2) SNP, H122, H123, H124
(3) K8 ..., K12 ..., KW10 ... (4) compact 69

Environmental Category A

Technical Data / Range of Application (1) Sheet steel housing with one or two doors
Type: SN 20..., SN 30..., SN 40..., SN 45..., SN 50..., SN 60..., SN 80..., SN 91..., SN 10 ..., SN 12
degree of protection IP66(one door), IP55 (two doors)
(2) Sheet steel console
Type : SNP, H122, H123, H124
degree of protection IP55
(3) Sheet steel Junction box with cover and mounted equipment rail
Type: K8 ..., K12 ..., KW10 ...
degree of protection IP 66
(4) Steel housing with Mounting plate or rail system
depth 120 - 600 mm, width 200 - 800 mm, hight 250 - 1600 mm
degree of protection IP 66 / IP69K

Dimension and accessories according to häwa catalogue

Test Standard Regulations for the Performance of Type Tests, Edition 2003

Documents Test report : UL File E93402 dated October 11, 1984; UL File E90604 dated November 30, 1984; KEMA Report 99-7034 dated August 23, 1999; VDE Report 2363900-9010-0001/104849 dated July 2008
Catalogue: häwa H03-89, häwa 24-9/5

Remarks None

Valid until 2014-01-21

Page 1 of 1

File No. I.J.02

Hamburg, 2009-01-30

Type Approval Symbol



Germanischer Lloyd

W. Voß
Wolfgang Voß

T. Reimer
Thomas Reimer